



# LX3V-2PT2ADV-BD

## User manual



Website: <http://www.we-con.com.cn/en>

Technical Support: [support@we-con.com.cn](mailto:support@we-con.com.cn)

Skype: fcwkkj

Phone: 86-591-87868869

QQ: 1043098682

Technical forum: <http://wecon.freeforums.net/>



# 1. Installation Instructions

---

Before installation, it is necessary to ensure that the associated equipment of the PLC host and the terminal of the BD module are reliably powered off.

This module comes with two standard terminals; please plug the terminals into the module terminals after wiring. Confirm the installation of host, module and wiring are correct and then power on.

## Caution:

- 1) When using the voltage output, ensure the external load resistance is no less than 2K $\Omega$ . If the external load resistance is less than 2K $\Omega$ , the output voltage will be lower than the normal value;
- 2) The input must not exceed the absolute maximum (-15V/+15V) or cause the module to be damaged;
- 3) The fastening torque is 0.3-0.6N.m. Firmly screw down to prevent malfunctions;
- 4) The PLC main unit of the LX3V can only use one BD module. Don't try to use two or more BD modules (these BD modules will not work);
- 5) This BD module only supports the following firmware versions or later. Users can check the PLC firmware version in D8001.
  - LX3VP:25103;
  - LX3VE: 25201;
  - LX3V-A2:25014;
  - LX3V-A1: 22006;

When mounting module to PLC, all the lights are blinking after power ON PLC, it means this PLC can't support it, please purchase new PLC.

## Warnings:

Cut off the electricity before installation/disassembly of the unit or connection of wires onto the unit, to prevent electric shock or product damage.

# 2. Features of LX3V-2PT2ADV-BD

---

- 1) It could use LX3V-2PT2ADV-BD to add 4 analog input points. It is internally installed in the top

of PLC, thus it is not necessary to change the PLC's installation area.

- 2) The analog digital conversion of LX3V-2PT2ADV-BD module is PT100 input (-100 °C ~ 600 °C), voltage input (-10V ~ 10V), and the data of all the channels after conversion are stored inside a special digital memory, but the converted characteristics of the analog data cannot be adjusted. The allocation of the relevant channel addresses is in the following table.

Table 2- 1

Address	Description		Address	Description
M8112	The flag of RTD type in CH1 OFF: RTD Type is PT100	ON: Disabled	D8112	CH1's temperature at 0.1 °C units
M8113	The flag of RTD type in CH1 OFF: RTD Type is PT100		D8113	CH2's temperature at 0.1 °C units
M8114	CH3: Flag of the input mode OFF: Voltage input mode		D8114	Digital value of CH3
M8115	CH4: flag of the input mode OFF: Voltage input mode		D8115	Digital value of CH4

## 3. Dimension

Table 3- 1




Figure 3- 1

IN-2PT part 2/3-wire PT100		IN-2ADV Part Input voltage ranges: -10V~10V	
L1+	CH1 PT100 signal input (+)	VI3+	CH3 voltage input (+)
L1-	CH1 PT100 signal input (-)	VI3-	CH3 voltage input (-)
▪	Disconnect	▪	Disconnect
L2+	CH2 PT100 signal input (+)	VI4+	CH4 voltage input (+)
L2-	CH2 PT100 signal input (-)	VI4-	CH4 voltage input (-)

### LED lights indicating:


- POW LED: Constantly ON when PLC power ON;
- COM LED: Lit when communicating PLC, OFF when timeout;
- CH1 LED: LED for CH1, constantly ON when analog signal in range, lit when analog signal out of


range (-100~600 °C). OFF when M8112 turns ON.

- CH2 LED: LED for CH2, constantly ON when analog signal in range, lit when analog signal out of range (-100~600 °C). OFF when M8113 turns ON.
- CH3 LED: LED for CH3, constantly ON when analog signal in range, lit when analog signal out of range (-10V~10V). OFF when M8114 turns ON.
- CH4 LED: LED for CH4, constantly ON when analog signal in range, lit when analog signal out of range (-10V~10V). OFF when M8115 turns ON.

## 4. Specifications

- 1) **General specification:** The same as the PLC main unit. (Please refer to the attached instructions supplied with the main unit of the PLC.)
- 2) **Power specification:** Powered from inside of the programmable controller.
- 3) **Performance specifications**

Item	Specification
<b>Power supply</b>	5VDC±10%, 70mA (Powered by PLC host)
<b>Temperature input (PT)</b>	
Analog input signal	PT100 sensor, 3 wires, 2 channels (CH1, CH2)
Sensor current	1mA sensor: 100Ω(PT100)
Compensation range	-100 °C - 600 °C
Digital output	-1000 – 6000 (Unit: 0.1 °C) 12 bits total, 11 bits for data and 1 bit for sign
Accuracy	0.2 °C - 0.3 °C
Overall accuracy	±1%
Conversion rate	50ms
Conversion characteristics	
<b>Analog input (ADV)</b>	
<b>Analog input range</b>	DC-10V~10V (input resistance 160KΩ). Note: If the input voltage exceeds ±15V, the unit will be damaged.
<b>Rated range</b>	-10V~10V: -2000~2000

The maximum display range	-2048~2048
Resolution	5mV[10V default scope 1/2000]
Precision	±0.5% of full scale
AD conversion time	One PLC scanning cycle
Input characteristics	
Insulation	No insulation in each PLC channel
Occupied points	None

## 5. Wire Connection

### Description:

- 1) 2-wire PT100: When using the first channel, L1- and VI- should be shorted with wires, and the two leads of the sensor should be connected with L1 + and L1- respectively. Similarly, use the second channel.
- 2) 3-wire PT100: When using the first channel, two of the same color leads are respectively connected to L1- and VI-, and the other different color is connected to L1 +. Similarly, use the second channel.

### Warning:

Make sure cut off the electricity before installation/disassembly, to prevent electric shock or product damages.

### Caution:

- 1) Please keep the signal cable from the high-voltage cable at lease 100mm.
- 2) The shielding wire cable shall be grounded. But their grounding point can be the same with high-voltage lines.
- 3) Never connect cable with forbidden size.
- 4) Fix the cable, so that the stress does not act on the terminal board or the cable connection area.
- 5) The screwing torque of the terminal is from 0.5 to 0.6N.m. Fasten tight to prevent malfunction.

6) Keep the redundant terminals empty.


## 5.1 Applicable Cables

Use AWG25-16 to connect the output equipment

The maximal screwing torque is from 0.5 to 0.6N.m


The use of different types of cables might cause poor contact between the terminals. It is better to use pressed terminals.

Table 5- 1


Line type	Cross sectional area(mm <sup>2</sup> )	End-of-pipe treatment	
AWG26	0.1288	Stranded cable: stripped jacket, rub Conductor, then connect the cable.	
.....	.....		
AWG16	1.309	Single-core cable: stripped jacket, Then connect the cable.	

## 5.2 Input Mode

### 1) PT100 input mode



### 2) Voltage Input Mode



- It is necessary to use shielded cable to transfer analog input. The cable shall be far away from the power line or other electrical wires that might cause electrical disturbance.
- If there is voltage ripple in the input or electrical disturbance outside, then a smoothing

capacitor can be added. (0.1uF~0.47uF, 25V)

## 6. Program Examples

The thermocouple PT100 inputs for each channel are stored in registers (D8112, D8113) in digital form. Values will be automatically stored when the “END” order is sent out. The value is calculated by the designated analog data conversion characteristics of the special auxiliary relays M8112 and M8113.


The input analog of all channels (-10V~10V) is stored inside the data memory (D8114, D8115) in the form of data. Values will be automatically stored when the “END” order is sent out. The value is calculated by the designated analog data conversion characteristics of the special auxiliary relays M8114 and M8115.

### 6.1 Basic Program Examples


#### Caution

- 1) M8112 and M8113 are used to analog to digital conversion for CH1 and CH2;
- 2) The PT part only supports PT100;
- 3) When M8112-M8115 is ON, the channels will not work, all show “0”;
- 4) Don’t try to change the value in D8112 or D8113, when finished the A/D conversion;

The following project sets CH1 and CH2 as PT100 input, and the value is storage in D0 and D2.



The following program can set CH3 and CH4 into voltage input mode. After ADV conversion, values of all channels are stored into D0 and D2.



- If the data are not stored into D0 or D2, then D8112, D8113 and D8114, D8115 can be simultaneously used on setting values and other orders, such as timer/counter.

## 6.2 Examples of Applications

Since the LX3V-2PT2DAV-BD does not have offset and gain functions, if it needs for the values out of the standard specifications, Additional programming orders will be needed to multiply or divide the converted value.


### Caution:

- Since the use of additional programming orders, the converted precision and resolution of the analog value are different with the specifications.
- The original range of the analog output does not change.

### 1) Thermocouple input mode

In RTD input mode, 2PT covert a analog value to a digital value in degrees Celsius. If in the program was a degree Fahrenheit as a unit it needs to be converted to Celsius value.

Fahrenheit and Celsius conversion formula, Fahrenheit = Celsius \* 9/5 + 32, the unit is 0.1 °C




### 2) Voltage Input Mode

Under the voltage input mode, the 2ADV will convert the analog value -10V~10V into data output -2000~2000. If the data range used in the application is 0-20000, then the range -2000~2000 must be converted into 0-20000, as is shown in the following program examples. The data converted from the analog values are stored in D8114 or D8115.



Since the data range is converted from -2000~2000 into 0-20000, therefore the resolution of the analog input is no longer just 5mV.



If the data range used in D0 is (0-20000), please refer to the following text: digital value in applications:  $D0 = 5 * (D8114 \text{ or } D8115) + 10000$ .

Use an example as follows based on the program of the above mentioned analog (under the situation of CH3)

```

M8000
├── [RST M8114]
├── [MUL K5 D8114 D2]
└── [ADD D2 K10000 D0]

```